



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-13**

**Lab# 101**

**Customer**

**Facility Name:** *Fairfield Inn & Suites*  
**Address:** *901 Providence Blvd.*  
*McCandless, PA 15237*

**Sample Collection**

**Date:** *7/22/25*  
**Time:** *1:09 PM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*  
**Source Type:** *Pool*

**Sample Final Analysis**

**Date:** *7/25/25*  
**Time:** *10:00 AM*  
**Analyst:** *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/23/25              | 12:40 PM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/23/25              | 12:40 PM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/22/25              | 6:00 PM  | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.8 SU   | 7.2 - 7.8 SU    | 7/22/25   | 1:09 PM | MM      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 7/22/25   | 1:09 PM | MM      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/22/25   | 1:09 PM | MM      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-13**

**Lab# 101**

**Customer**

**Facility Name:** *Fairfield Inn & Suites*  
**Address:** *901 Providence Blvd.*  
*McCandless, PA 15237*

**Sample Collection**

**Date:** *7/22/25*  
**Time:** *1:09 PM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*  
**Source Type:** *Pool*

**Sample Final Analysis**

**Date:** *7/25/25*  
**Time:** *10:00 AM*  
**Analyst:** *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/23/25              | 12:40 PM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/23/25              | 12:40 PM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/22/25              | 6:00 PM  | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.8 SU   | 7.2 - 7.8 SU    | 7/22/25   | 1:09 PM | MM      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 7/22/25   | 1:09 PM | MM      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/22/25   | 1:09 PM | MM      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor