

## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 **APM 3** 

Lab# 2525

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Torrent of Upper St. Clair

Address: 2565 Boyce Plaza Rd.

Upper St. Clair, PA 15241

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/16/25

Time: 2:01 PM Method: Grab

Sample Final Analysis

Date: 6/19/25 Time: 10:00 AM

Time: 10:00 AM Analyst: AS

Accredited Analysis Results		Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	6/17/25	11:30 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	6/17/25	11:30 AM	EB	SM 9222B	
Standard plate count:	570/ml	200/ml	6/16/25	6:00 PM	SL	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/16/25	2:01 PM	AF	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/16/25	2:01 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	2:01 PM	AF	Visual

## Sample comments

andre Smith

( When exceeding reporting limit pool or spa is unfit)



## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 **APM 3** 

Lab# 2525

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Torrent of Upper St. Clair

Address: 2565 Boyce Plaza Rd.

Upper St. Clair, PA 15241

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/16/25

Time: 2:01 PM Method: Grab

Sample Final Analysis

Date: 6/19/25 Time: 10:00 AM

Time: 10:00 AM Analyst: AS

Accredited Analysis Results		Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	6/17/25	11:30 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	6/17/25	11:30 AM	EB	SM 9222B	
Standard plate count:	570/ml	200/ml	6/16/25	6:00 PM	SL	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/16/25	2:01 PM	AF	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/16/25	2:01 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	2:01 PM	AF	Visual

## Sample comments

andre Smith

( When exceeding reporting limit pool or spa is unfit)