



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 283

Customer

Facility Name: *South Park High School*

Address: *2005 Eagle Ridge Rd.*
South Park, PA 15129

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *1/21/26*

Time: *11:46 AM*

Method: *Grab*

Sample Final Analysis

Date: *1/24/26*

Time: *8:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/22/26 11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/22/26 11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/21/26 5:21 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	1/21/26 11:46 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	1/21/26 11:46 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/21/26 11:46 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor