

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

C-10

Lab ID No. 02-04041

Lab# 2698

Customer

Facility Name:

Highland House Tower

Address:

5700 BunkerhillSt

Pittsburgh, PA 15206

Matrix:

Source Type:

Recreational Water

Pool

Sample Collection

Date:

8/26/25 5:00 PM

Time: Method:

Grab

Sample Final Analysis

Date:

8/29/25

Time:

10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/25	12:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/25	12:00 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/26/25	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/26/25	5:00 PM	DNP	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/26/25	5:00 PM	DNP	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/25	5:00 PM	DNP	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith