



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-13

Lab# 2196

Customer

Facility Name: Forest Oaks Wexford

Address: Forest Oaks Dr.
Wexford, PA 15090

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/12/25

Time: 2:14 PM

Method: Grab

Sample Final Analysis

Date: 8/15/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	5:35 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/12/25	2:14 PM	MM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/12/25	2:14 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	2:14 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-13

Lab# 2196

Customer

Facility Name: Forest Oaks Wexford

Address: Forest Oaks Dr.
Wexford, PA 15090

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/12/25

Time: 2:14 PM

Method: Grab

Sample Final Analysis

Date: 8/15/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	5:35 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/12/25	2:14 PM	MM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/12/25	2:14 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	2:14 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor