



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-15**

**Lab# 483**

**Customer**

Facility Name: YMCA - Schneider  
Address: 2001 Ehrman Rd  
Cranberry, PA 16066

Matrix: Recreational Water  
Source Type: Small Pool

**Sample Collection**

Date: 7/1/25  
Time: 12:07 PM  
Method: Grab

**Sample Final Analysis**

Date: 7/4/25  
Time: 9:30 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	3:25 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/1/25	12:07 PM	ZR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/1/25	12:07 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	12:07 PM	ZR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-15**

**Lab# 483**

**Customer**

Facility Name: YMCA - Schneider  
Address: 2001 Ehrman Rd  
Cranberry, PA 16066

Matrix: Recreational Water  
Source Type: Small Pool

**Sample Collection**

Date: 7/1/25  
Time: 12:07 PM  
Method: Grab

**Sample Final Analysis**

Date: 7/4/25  
Time: 9:30 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	3:25 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/1/25	12:07 PM	ZR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/1/25	12:07 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	12:07 PM	ZR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor