



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2373

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

		<b><u>Sample Collection</u></b>	
Facility Name:	Nob Hill	Date:	6/2/25
Address:	3000 Swallow Hill Rd. Pittsburgh, PA 15220	Time:	1:24 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		

  

		<b><u>Sample Final Analysis</u></b>	
Matrix:	Recreational Water	Date:	6/5/25
Source Type:	Pool	Time:	9:30 AM
		Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	11:00 AM	EB
Total coliforms:	0/100mls	2/100mls	6/3/25	11:00 AM	EB
Standard plate count:	0/ml	200/ml	6/2/25	6:30 PM	SL

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/2/25	1:24 PM	CW
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/2/25	1:24 PM	CW
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	1:24 PM	CW

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2373

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

		<b><u>Sample Collection</u></b>	
Facility Name:	Nob Hill	Date:	6/2/25
Address:	3000 Swallow Hill Rd. Pittsburgh, PA 15220	Time:	1:24 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		

  

		<b><u>Sample Final Analysis</u></b>	
Matrix:	Recreational Water	Date:	6/5/25
Source Type:	Pool	Time:	9:30 AM
		Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	11:00 AM	EB
Total coliforms:	0/100mls	2/100mls	6/3/25	11:00 AM	EB
Standard plate count:	0/ml	200/ml	6/2/25	6:30 PM	SL

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/2/25	1:24 PM	CW
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/2/25	1:24 PM	CW
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	1:24 PM	CW

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor