

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

APM 3

Lab ID No. 02-04041

Lab# 2328

Customer American Pools Management

> 3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Longvue C.C.

Address: 400 Longue Vue Dr.

Verona, PA 15147

Matrix: Recreational Water

Source Type: Baby Pool Sample Collection

Date: 8/18/25

9:22 AM Time: Method: Grab

Sample Final Analysis

Date:

8/21/25 Time: 9:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	1/0/00	9:00 AM	SL	SM 9222G	
Total coliforms:	0/100mls	2/100mls	8/19/25	9:00 AM	SL	SM 9222B	
Standard plate count:	0/ml	200/ml	8/18/25	2:42 PM	SL	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	8/18/25	9:22 AM	EH	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/18/25	9:22 AM	EH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/18/25	9:22 AM	EH	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith Andre Smith, Lead Supervisor