



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2265

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Highlands of Montour Run*
Address: *100 Lincoln Highlands Dr.*
Coraopolis, PA 15108

Date: 6/17/25
Time: 10:27 AM
Method: Grab

Sample Final Analysis

Matrix: *Recreational Water*
Source Type: *Pool*

Date: 6/20/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25 10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25 10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25 4:30 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/17/25 10:27 AM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/17/25 10:27 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25 10:27 AM	AH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2265

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Highlands of Montour Run
Address: 100 Lincoln Highlands Dr.
Coraopolis, PA 15108

Date: 6/17/25
Time: 10:27 AM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Pool

Date: 6/20/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	4:30 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/17/25	10:27 AM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/17/25	10:27 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	10:27 AM	AH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor