



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E-1**

**Lab# 250**

**Customer**

Facility Name: Penn Towers  
Address: 1100 Penn Center Blvd.  
Pittsburgh, PA 15235

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 9/3/25  
Time: 10:35 AM  
Method: Grab

**Sample Final Analysis**

Date: 9/6/25  
Time: 2:00 PM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/4/25	9:15 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/4/25	9:15 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/3/25	4:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.2 SU	7.2 - 7.8 SU	9/3/25	10:35 AM	SH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/3/25	10:35 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/3/25	10:35 AM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor