



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-3

Lab# 470

Customer

Facility Name: Hampton Inn
Address: 62 Pine Ridge Rd.
Blairsville, PA 15717

Sample Collection

Date: 9/15/25
Time: 11:00 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 9/18/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/16/25	10:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/16/25	10:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/15/25	5:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	9/15/25	11:00 AM	DNP	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	9/15/25	11:00 AM	DNP	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/15/25	11:00 AM	DNP	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor