Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 2075

Customer

Facility Name:	*Camp Guyasuta*
Address:	*300 23rd Street*
	Sharpsburg, PA 15215
Matrix:	*Recreational Water*
Source Type:	*Splash Pool*

Sample Collection

Date:	*8/5/25*
Time:	*10:20 AM*
Method:	*Grab*

Sample Final Analysis

Date:	*8/8/25*
Time:	*8:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	2:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	2:00 PM	AH	SM 9222B
Standard plate count:	5700/ml	200/ml	8/5/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/5/25	10:20 AM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/5/25	10:20 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	10:20 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 2075

Customer

Facility Name:	*Camp Guyasuta*
Address:	*300 23rd Street*
	Sharpsburg, PA 15215
Matrix:	*Recreational Water*
Source Type:	*Splash Pool*

Sample Collection

Date:	*8/5/25*
Time:	*10:20 AM*
Method:	*Grab*

Sample Final Analysis

Date:	*8/8/25*
Time:	*8:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	2:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	2:00 PM	AH	SM 9222B
Standard plate count:	5700/ml	200/ml	8/5/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/5/25	10:20 AM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/5/25	10:20 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	10:20 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor