

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

0.40

S-12

Lab ID No. 02-04041

Lab# 296

Sample Collection

Customer

Facility Name: Steel Valley High School Date: 7/28/25
Time: 11:30 AM

Address: 3113 Main Street Method: Grab

Munhall, PA 15120

Matrix: Recreational Water Sample Final Analysis

Date: 7/31/25

Time: 9:00 AM
Source Type: Deep End Analyst: AS

Accredited Analysis Results **Reporting limit Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent Absent 7/29/25 10:30 AM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 7/29/25 10:30 AM AΗ SM 9222B Standard plate count: 300/ml 200/ml 7/28/25 5:05 PM SL SM 9215B

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method | |
|----------------|----------|-----------------|-----------|----------|---------|--------|--|
| рН: | 7.8 SU | 7.2 - 7.8 SU | 7/28/25 | 11:30 AM | SL | DPD | |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 7/28/25 | 11:30 AM | SL | DPD | |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/28/25 | 11:30 AM | SL | Visual | |

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

0.40

S-12

Lab ID No. 02-04041

Lab# 296

Sample Collection

Customer

Facility Name: Steel Valley High School Date: 7/28/25
Time: 11:30 AM

Address: 3113 Main Street Method: Grab

Munhall, PA 15120

Matrix: Recreational Water Sample Final Analysis

Date: 7/31/25

Time: 9:00 AM
Source Type: Deep End Analyst: AS

Accredited Analysis Results **Reporting limit Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent Absent 7/29/25 10:30 AM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 7/29/25 10:30 AM AΗ SM 9222B Standard plate count: 300/ml 200/ml 7/28/25 5:05 PM SL SM 9215B

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method | |
|----------------|----------|-----------------|-----------|----------|---------|--------|--|
| рН: | 7.8 SU | 7.2 - 7.8 SU | 7/28/25 | 11:30 AM | SL | DPD | |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 7/28/25 | 11:30 AM | SL | DPD | |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/28/25 | 11:30 AM | SL | Visual | |

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)