



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
C-11

Lab# 067

Customer

Facility Name: Cork Factory

Address: 2349 Rail Road St.
Pittsburgh, PA 15222

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 6/3/25
Time: 8:50 AM
Method: Grab

Sample Final Analysis

Date: 6/6/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	6/4/25 11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25 11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25 5:15 PM	EB	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	6/4/25 12:00 PM	AH	SM 9230C
---------------------	----------	----------	-----------------	----	----------


Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	8.0 SU	7.2 - 7.8 SU	6/3/25 8:50 AM	LM	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/3/25 8:50 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25 8:50 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
C-11

Lab# 067

Customer

Facility Name: Cork Factory

Address: 2349 Rail Road St.
Pittsburgh, PA 15222

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 6/3/25
Time: 8:50 AM
Method: Grab

Sample Final Analysis

Date: 6/6/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	5:15 PM	EB	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/4/25	12:00 PM	AH	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/3/25	8:50 AM	LM	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/3/25	8:50 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	8:50 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor