



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-16**

**Lab# 160**

**Customer**

**Facility Name:** *Holiday Inn Express*  
**Address:** *810 Highland Meadow Dr.*  
*Washington, PA 15301*

**Sample Collection**

**Date:** *8/5/25*  
**Time:** *11:57 AM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*

**Sample Final Analysis**

**Date:** *8/8/25*  
**Time:** *8:30 AM*  
**Analyst:** *AS*

**Source Type:** *Spa*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Escherichia Coli:	Absent	Absent	8/6/25	10:15 AM	AH	SM 9222G
-------------------	--------	--------	--------	----------	----	----------

Total coliforms:	0/100mls	2/100mls	8/6/25	10:15 AM	AH	SM 9222B
------------------	----------	----------	--------	----------	----	----------

Standard plate count:	0/ml	200/ml	8/5/25	5:00 PM	AS	SM 9215B
-----------------------	------	--------	--------	---------	----	----------

<b>Additional Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Fecal Streptococcus	0/100mls	2/100mls	8/6/25	8:25 AM	PS	SM 9230C
---------------------	----------	----------	--------	---------	----	----------

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>
-----------------------	----------------	------------------------	------------------	----------------	---------------

pH:	7.4 SU	7.2 - 7.8 SU	8/5/25	11:57 AM	GR	DPD
-----	--------	--------------	--------	----------	----	-----

Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/5/25	11:57 AM	GR	DPD
-----------	----------	----------------	--------	----------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	8/5/25	11:57 AM	GR	Visual
------------	-------	-----------	--------	----------	----	--------

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-16**

**Lab# 160**

**Customer**

**Facility Name:** *Holiday Inn Express*  
**Address:** *810 Highland Meadow Dr.*  
*Washington, PA 15301*

**Sample Collection**

**Date:** *8/5/25*  
**Time:** *11:57 AM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*

**Sample Final Analysis**

**Date:** *8/8/25*  
**Time:** *8:30 AM*  
**Analyst:** *AS*

**Source Type:** *Spa*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Escherichia Coli:	Absent	Absent	8/6/25	10:15 AM	AH SM 9222G
-------------------	--------	--------	--------	----------	-------------

Total coliforms:	0/100mls	2/100mls	8/6/25	10:15 AM	AH SM 9222B
------------------	----------	----------	--------	----------	-------------

Standard plate count:	0/ml	200/ml	8/5/25	5:00 PM	AS SM 9215B
-----------------------	------	--------	--------	---------	-------------

<b>Additional Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Fecal Streptococcus	0/100mls	2/100mls	8/6/25	8:25 AM	PS SM 9230C
---------------------	----------	----------	--------	---------	-------------

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>
-----------------------	----------------	------------------------	------------------	----------------	---------------

pH:	7.4 SU	7.2 - 7.8 SU	8/5/25	11:57 AM	GR DPD
-----	--------	--------------	--------	----------	--------

Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/5/25	11:57 AM	GR DPD
-----------	----------	----------------	--------	----------	--------

Turbidity:	1 NTU	1 - 2 NTU	8/5/25	11:57 AM	GR Visual
------------	-------	-----------	--------	----------	-----------

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
Andre Smith, Lead Supervisor