



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 333

<u>Customer</u>		<u>Sample Collection</u>	
Facility Name:	Western PA School	Date:	11/11/25
Address:	201 N. Bellefield Ave. Pittsburgh, PA 15213	Time:	9:43 AM
Matrix:		<u>Sample Final Analysis</u>	
Source Type:	Recreational Water	Date:	11/14/25
	Therapy Pool	Time:	10:00 AM
		Analyst:	AS
Accredited Analysis	Results	Reporting limit	Incubation Date/Time
Escherichia Coli:	Absent	Absent	11/12/25 9:30 AM
Total coliforms:	0/100mls	2/100mls	11/12/25 9:30 AM
Standard plate count:	0/ml	200/ml	11/11/25 2:30 PM

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	11/11/25 9:43 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	11/11/25 9:43 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/11/25 9:43 AM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor