



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 2075

Customer

Facility Name: *Camp Guyasuta*
Address: *300 23rd Street*
Sharpsburg, PA 15215

Matrix: *Recreational Water*

Source Type: *Splash Pool*

Sample Collection

Date: *6/10/25*
Time: *9:55 AM*
Method: *Grab*

Sample Final Analysis

Date: *6/13/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	4:33 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/10/25	9:55 AM	BH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/10/25	9:55 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	9:55 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 2075

Customer

Facility Name: *Camp Guyasuta*
Address: *300 23rd Street*
Sharpsburg, PA 15215

Matrix: *Recreational Water*

Source Type: *Splash Pool*

Sample Collection

Date: *6/10/25*
Time: *9:55 AM*
Method: *Grab*

Sample Final Analysis

Date: *6/13/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	4:33 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/10/25	9:55 AM	BH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/10/25	9:55 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	9:55 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor