



**Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665**

**Laboratory Analysis Report**

Lab ID No. 02-04041

C-1

Lab# 349

<b>Customer</b>		<b>Sample Collection</b>				
Facility Name:	Courtyard - University Center	Date:	9/2/25			
Address:	100 Lytton Ave. Pittsburgh, PA 15213	Time:	10:20 AM			
					<b>Sample Final Analysis</b>	
Matrix:	Recreational Water	Date:	9/5/25			
Source Type:	Pool	Time:	10:00 AM			
<b>Accredited Analysis</b>		<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	9/3/25	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/25	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/2/25	4:50 PM	AS	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
pH:	7.6 SU	7.2 - 7.8 SU	9/2/25	10:20 AM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/2/25	10:20 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/2/25	10:20 AM	SL	Visual

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor