



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-11

Lab# 085

Customer

Facility Name: *Deer Lakes H.S.*

Address: *163 East Union Road*
Cheswick, PA 15024

Matrix: *Recreational Water*

Source Type: *Shallow End*

Sample Collection

Date: *7/15/25*
Time: *2:15 PM*
Method: *Grab*

Sample Final Analysis

Date: *7/18/25*
Time: *9:30 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/16/25 | 10:10 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/16/25 | 10:10 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/15/25 | 4:00 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 7/15/25 | 2:15 PM | SH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/15/25 | 2:15 PM | SH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/15/25 | 2:15 PM | SH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-11

Lab# 085

Customer

Facility Name: *Deer Lakes H.S.*

Address: *163 East Union Road*
Cheswick, PA 15024

Matrix: *Recreational Water*

Source Type: *Shallow End*

Sample Collection

Date: *7/15/25*
Time: *2:15 PM*
Method: *Grab*

Sample Final Analysis

Date: *7/18/25*
Time: *9:30 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/16/25 | 10:10 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/16/25 | 10:10 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/15/25 | 4:00 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 7/15/25 | 2:15 PM | SH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/15/25 | 2:15 PM | SH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/15/25 | 2:15 PM | SH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor