



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 009**

**Customer**

**Facility Name:** Arsenal Middle  
**Address:** 3900 Butler St.  
Pittsburgh, PA 15201

**Matrix:** Recreational Water

**Source Type:** Pool Deep

**Sample Collection**

**Date:** 7/23/25  
**Time:** 3:15 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/25/25  
**Time:** 2:00 PM  
**Analyst:** AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/23/25	4:27 PM	SL	SM 9222G
Total coliforms:	0/100mls	A	7/23/25	4:27 PM	SL	SM 9222B
Standard plate count:	0/ml	A	7/23/25	4:27 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	7/23/25	3:15 PM	CW	DPD
Chlorine:	3.0 mg/l	A	7/23/25	3:15 PM	CW	DPD
Turbidity:	1 NTU	A	7/23/25	3:15 PM	CW	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 009**

**Customer**

**Facility Name:** Arsenal Middle  
**Address:** 3900 Butler St.  
Pittsburgh, PA 15201

**Matrix:** Recreational Water

**Source Type:** Pool Deep

**Sample Collection**

**Date:** 7/23/25  
**Time:** 3:15 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/25/25  
**Time:** 2:00 PM  
**Analyst:** AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/23/25	4:27 PM	SL	SM 9222G
Total coliforms:	0/100mls	A	7/23/25	4:27 PM	SL	SM 9222B
Standard plate count:	0/ml	A	7/23/25	4:27 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	7/23/25	3:15 PM	CW	DPD
Chlorine:	3.0 mg/l	A	7/23/25	3:15 PM	CW	DPD
Turbidity:	1 NTU	A	7/23/25	3:15 PM	CW	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor