

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 **W-12**

Lab# 2014

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Allegheny C.C. Date: 6/25/25
Time: 12:15 PM

Address: 250 Country Club Rd Method: Grab Sewickley, PA 15143

Sample Final Analysis

Matrix: Recreational Water Date: 6/27/25

Source Type: Pool Time: 4:30 PM
Analyst: AS

Accredited Analysis Results Reporting limit **Analyst** Method Incubation Date/Time Escherichia Coli: Absent Absent 6/25/25 3:40 PM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 6/25/25 3:40 PM AΗ SM 9222B Standard plate count: 0/ml 200/ml 6/25/25 2:44 PM EB SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/25/25	12:15 PM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/25/25	12:15 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/25/25	12:15 PM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 **W-12**

Lab# 2014

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Allegheny C.C. Date: 6/25/25
Time: 12:15 PM

Address: 250 Country Club Rd Method: Grab Sewickley, PA 15143

Sample Final Analysis

Matrix: Recreational Water Date: 6/27/25

Source Type: Pool Time: 4:30 PM
Analyst: AS

Accredited Analysis Results Reporting limit **Analyst** Method Incubation Date/Time Escherichia Coli: Absent Absent 6/25/25 3:40 PM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 6/25/25 3:40 PM AΗ SM 9222B Standard plate count: 0/ml 200/ml 6/25/25 2:44 PM EB SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/25/25	12:15 PM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/25/25	12:15 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/25/25	12:15 PM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor