



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2709

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: District

Date: 7/29/25

Address: 1759 Waterfront Pl
Pittsburgh, PA 15222

Time: 9:20 AM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 8/1/25

Source Type: Pool

Time: 9:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|----------------------------|----------------|------------------------|-------------------|------------------|----------------|---------------|
| Escherichia Coli: | Absent | Absent | 7/30/25 | 10:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/30/25 | 10:30 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/29/25 | 4:30 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|---------|--------|--------|
| pH: | 7.8 SU | 7.2 - 7.8 SU | 7/29/25 | 9:20 AM | LM | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/29/25 | 9:20 AM | LM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/29/25 | 9:20 AM | LM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2709

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *District*

Date: 7/29/25

Address: *1759 Waterfront Pl*
Pittsburgh, PA 15222

Time: 9:20 AM

Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Date: 8/1/25

Source Type: *Pool*

Time: 9:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|----------------------------|----------------|------------------------|-------------------|------------------|----------------|---------------|
| Escherichia Coli: | Absent | Absent | 7/30/25 | 10:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/30/25 | 10:30 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/29/25 | 4:30 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|---------|--------|--------|
| pH: | 7.8 SU | 7.2 - 7.8 SU | 7/29/25 | 9:20 AM | LM | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/29/25 | 9:20 AM | LM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/29/25 | 9:20 AM | LM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor