



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 457

Customer

Facility Name: Olympic Swim Club

Address: 517 Twin Oaks Dr.
Pittsburgh, PA 15235

Matrix: Recreational Water

Source Type: Indoor Pool

Sample Collection

Date: 6/3/25
Time: 8:52 AM
Method: Grab

Sample Final Analysis

Date: 6/6/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	3:25 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/3/25	8:52 AM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/3/25	8:52 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	8:52 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 457

Customer

Facility Name: Olympic Swim Club

Address: 517 Twin Oaks Dr.
Pittsburgh, PA 15235

Matrix: Recreational Water

Source Type: Indoor Pool

Sample Collection

Date: 6/3/25
Time: 8:52 AM
Method: Grab

Sample Final Analysis

Date: 6/6/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	3:25 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/3/25	8:52 AM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/3/25	8:52 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	8:52 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor