



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

E - 11

Lab# 273

Customer

Facility Name: Seven Springs Resort

Address: 777 Waterwheel Dr.
Champion, PA 15622

Matrix: Recreational Water

Source Type: Spa-Stowe

Sample Collection

Date: 5/27/25

Time: 12:00 PM

Seven Spring Method: Grab

Sample Final Analysis

Date: 5/30/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:45 AM	EB
Total coliforms:	0/100mls	2/100mls	5/28/25	9:45 AM	EB
Standard plate count:	0/ml	200/ml	5/27/25	5:40 PM	AS

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	1/0/00	12:00 AM	0

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/27/25	12:00 PM	JC
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/27/25	12:00 PM	JC
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	12:00 PM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

E - 11

Lab# 273

Customer

Facility Name: Seven Springs Resort

Address: 777 Waterwheel Dr.
Champion, PA 15622

Matrix: Recreational Water

Source Type: Spa-Stowe

Sample Collection

Date: 5/27/25

Time: 12:00 PM

Seven Spring Method: Grab

Sample Final Analysis

Date: 5/30/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:45 AM	EB
Total coliforms:	0/100mls	2/100mls	5/28/25	9:45 AM	EB
Standard plate count:	0/ml	200/ml	5/27/25	5:40 PM	AS

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	1/0/00	12:00 AM	0

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/27/25	12:00 PM	JC
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/27/25	12:00 PM	JC
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	12:00 PM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor