

Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2665

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Georgetown Estates Sample Collection

Date: 7/1/2

Name: Georgetown Estates Date: 7/1/25
Time: 10:13 AM
s: Old Farm Rd. Method: Grab

Address: Old Farm Rd. Method: Grab Lawrence, PA 15055

Matrix: Recreational Water Sample Final Analysis

Date: 7/4/25

Source Type: Large Pool Time: 9:30 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	11:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	11:20 AM	EB	SM 9222B
Standard plate count:	570/ml	200/ml	7/1/25	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time		Method
pH:	7.2 SU	7.2 - 7.8 SU	7/1/25	10:13 AM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/1/25	10:13 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	10:13 AM	AF	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)



Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2665

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Georgetown Estates Sample Collection

Date: 7/1/2

Name: Georgetown Estates Date: 7/1/25
Time: 10:13 AM
s: Old Farm Rd. Method: Grab

Address: Old Farm Rd. Method: Grab Lawrence, PA 15055

Matrix: Recreational Water Sample Final Analysis

Date: 7/4/25

Source Type: Large Pool Time: 9:30 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	11:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	11:20 AM	EB	SM 9222B
Standard plate count:	570/ml	200/ml	7/1/25	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time		Method
pH:	7.2 SU	7.2 - 7.8 SU	7/1/25	10:13 AM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/1/25	10:13 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	10:13 AM	AF	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)