



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**N-3**

**Lab# 447**

**Customer**

**Facility Name:** Fox Chapel High School

**Address:** 611 Field Club Rd  
Pittsburgh, PA 15238

**Matrix:** Recreational Water

**Source Type:** Deep End

**Sample Collection**

**Date:** 11/4/25

**Time:** 9:47 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 11/7/25

**Time:** 10:00 AM

**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/5/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/5/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	11/4/25	4:32 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	11/4/25	9:47 AM	AMH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	11/4/25	9:47 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/4/25	9:47 AM	AMH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor