



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 369

Customer

Facility Name: Towne Place Suites

Address: Westside Square Dr.
Mercer, PA 16137

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 11/3/25

Time: 1:25 PM

Method: Grab

Sample Final Analysis

Date: 11/6/25

Time: 11:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/4/25	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/4/25	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	11/3/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	11/3/25	1:25 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	11/3/25	1:25 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/3/25	1:25 PM	BH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor