



Lab ID No. 02-04041

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Service

Lab# 012

<u>Customer</u>		<u>Sample Collection</u>	
Facility Name:	Atrium	Date:	2/26
Address:	307 South Dithridge Pittsburgh, PA 15213	Time:	10:15 AM
Matrix:		<u>Sample Final Analysis</u>	
Source Type:	Recreational Water	Date:	2/5/26
		Time:	10:30 AM
		Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	2/3/26	10:00 AM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	2/3/26	10:00 AM	SL SM 9222B
Standard plate count:	0/ml	200/ml	2/2/26	4:10 PM	SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	2/2/26	10:15 AM	AG DPD
Chlorine:	2.4 mg/l	1.0 - 5.0 mg/l	2/2/26	10:15 AM	AG DPD
Turbidity:	1 NTU	1 - 2 NTU	2/2/26	10:15 AM	AG Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor