



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-3

Lab# 476

Customer

Facility Name: Comfort Suites

Address: 140 Stroehman Dr.
Altoona, PA 16601

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 1/27/26

Time: 11:16 AM

Method: Grab

Sample Final Analysis

Date: 1/30/26

Time: 12:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/28/26	11:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/28/26	11:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/27/26	5:16 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	1/27/26	11:16 AM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	1/27/26	11:16 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/27/26	11:16 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor