



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2504

Customer

Facility Name: *St Clair Country Club*

Address: *2300 Old Washington Rd.*
Pittsburgh, PA 15241

Matrix: *Recreational Water*

Source Type: *Deep End*

Sample Collection

Date: *8/11/25*
Time: *3:45 PM*
Method: *Grab*

Sample Final Analysis

Date: *8/14/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	5:20 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	3:45 PM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/11/25	3:45 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	3:45 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2504

Customer

Facility Name: *St Clair Country Club*

Address: *2300 Old Washington Rd.*
Pittsburgh, PA 15241

Matrix: *Recreational Water*

Source Type: *Deep End*

Sample Collection

Date: *8/11/25*
Time: *3:45 PM*
Method: *Grab*

Sample Final Analysis

Date: *8/14/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	5:20 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	3:45 PM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/11/25	3:45 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	3:45 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor