



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2252**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:*      *Hidden Valley Manor*  
  
*Address:*            *2774 Bingham Dr.*  
                              *Upper St. Clair, PA 15241*

*Date:*                    *7/14/25*  
*Time:*                 *1:57 PM*  
*Method:*              *Grab*

**Sample Final Analysis**

*Matrix:*                *Recreational Water*  
  
*Source Type:*        *Pool*

*Date:*                    *7/17/25*  
*Time:*                 *8:30 AM*  
*Analyst:*               *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	7/15/25	10:45 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	10:45 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	5:00 PM	EB	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.6 SU	7.2 - 7.8 SU	7/14/25	1:57 PM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/14/25	1:57 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	1:57 PM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

---

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2252**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:*      *Hidden Valley Manor*  
  
*Address:*            *2774 Bingham Dr.*  
                              *Upper St. Clair, PA 15241*

*Date:*                    *7/14/25*  
*Time:*                 *1:57 PM*  
*Method:*              *Grab*

**Sample Final Analysis**

*Matrix:*                *Recreational Water*  
  
*Source Type:*        *Pool*

*Date:*                    *7/17/25*  
*Time:*                 *8:30 AM*  
*Analyst:*               *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	7/15/25	10:45 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	10:45 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	5:00 PM	EB	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.6 SU	7.2 - 7.8 SU	7/14/25	1:57 PM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/14/25	1:57 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	1:57 PM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

---

Andre Smith, Lead Supervisor