



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-11**

**Lab# 2266**

**Customer**

Facility Name: *Hillcrest Country Club*  
  
Address: *3411 Leechburg Road*  
*Lower Burrell, PA 15068*

Matrix: *Recreational Water*

Source Type: *Large Pool*

**Sample Collection**

Date: *7/8/25*  
Time: *11:40 AM*  
Method: *Grab*

**Sample Final Analysis**

Date: *7/11/25*  
Time: *9:00 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	5:35 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/8/25	11:40 AM	SH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/8/25	11:40 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	11:40 AM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-11**

**Lab# 2266**

**Customer**

Facility Name: *Hillcrest Country Club*  
  
Address: *3411 Leechburg Road*  
*Lower Burrell, PA 15068*

Matrix: *Recreational Water*

Source Type: *Large Pool*

**Sample Collection**

Date: *7/8/25*  
Time: *11:40 AM*  
Method: *Grab*

**Sample Final Analysis**

Date: *7/11/25*  
Time: *9:00 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	5:35 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/8/25	11:40 AM	SH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/8/25	11:40 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	11:40 AM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor