



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-10**

**Lab# 176**

**Customer**

Facility Name: Hyatt House- Bloomfield

Address: 5335 Baum Blvd.  
Pittsburgh, Pa 15224

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 6/16/25  
Time: 1:00 PM  
Method: Grab

**Sample Final Analysis**

Date: 6/19/25  
Time: 10:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	10:05 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	10:05 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	2:46 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/16/25	1:00 PM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/16/25	1:00 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	1:00 PM	LM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
Andrea Smith



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-10**

**Lab# 176**

**Customer**

Facility Name: Hyatt House- Bloomfield

Address: 5335 Baum Blvd.  
Pittsburgh, Pa 15224

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 6/16/25  
Time: 1:00 PM  
Method: Grab

**Sample Final Analysis**

Date: 6/19/25  
Time: 10:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	10:05 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	10:05 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	2:46 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/16/25	1:00 PM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/16/25	1:00 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	1:00 PM	LM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
Andrea Smith