



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**E-2**

**Lab# 065**

**Customer**

**Facility Name:** Wingate  
**Address:** 106 Bair Blvd  
New Stanton, PA 15672

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 11/10/25  
**Time:** 9:33 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 11/13/25  
**Time:** 10:00 AM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 11/11/25             | 9:50 AM | JC      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 11/11/25             | 9:50 AM | JC      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 11/10/25             | 5:10 PM | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.2 SU   | 7.2 - 7.8 SU    | 11/10/25  | 9:33 AM | JC      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 11/10/25  | 9:33 AM | JC      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 11/10/25  | 9:33 AM | JC      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor