



Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665

Lab ID No. 02-04041

W-2

Lab# 413

## Laboratory Analysis Report

### Customer

Facility Name: Town Place Airport  
Address: 1006 Sutherland Dr.  
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Pool

### Sample Collection

Date: 12/29/25  
Time: 12:15 PM  
Method: Grab

### Sample Final Analysis

Date: 1/1/26  
Time: 10:00 AM  
Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 12/30/25             | 9:50 AM | JC      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 12/30/25             | 9:50 AM | JC      | SM 9222B |
| Standard plate count: | 120/ml   | 200/ml          | 12/29/25             | 3:15 PM | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | 12/29/25  | 12:15 PM | VH      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 12/29/25  | 12:15 PM | VH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 12/29/25  | 12:15 PM | VH      | Visual |

### Sample comments

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor