



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2056

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: Brentwood Borough Pool

Sample Collection

Date: 6/11/25

Time: 9:40 AM

Method: Grab

Address: Park Dr.
Pittsburgh, PA 15227

Sample Final Analysis

Date: 6/13/25

Time: 3:00 PM

Analyst: AS

Matrix: Recreational Water

Source Type: Deep End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25 3:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25 3:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/11/25 3:33 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/11/25 9:40 AM	DW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/11/25 9:40 AM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25 9:40 AM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith". The signature is fluid and cursive, with "Andre" on top and "Smith" below it.

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2056

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: Brentwood Borough Pool

Sample Collection

Date: 6/11/25

Time: 9:40 AM

Method: Grab

Address: Park Dr.
Pittsburgh, PA 15227

Sample Final Analysis

Date: 6/13/25

Time: 3:00 PM

Analyst: AS

Matrix: Recreational Water

Source Type: Deep End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25 3:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25 3:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/11/25 3:33 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/11/25 9:40 AM	DW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/11/25 9:40 AM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25 9:40 AM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor