



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 332

Customer

Facility Name: West Mifflin High School
Address: 91 Commonwealth Avenue
West Mifflin, PA 15122

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 1/29/26
Time: 8:40 AM
Method: Grab

Sample Final Analysis

Date: 1/31/26
Time: 5:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/29/26	5:17 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/29/26	5:17 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	1/29/26	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	1/29/26	8:40 AM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	1/29/26	8:40 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/29/26	8:40 AM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)