



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 046

Customer

Facility Name: Carrick High School
Address: 125 Parkfield St.
Pittsburgh, PA 15210

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 8/25/25
Time: 12:30 PM
Method: Grab

Sample Final Analysis

Date: 8/28/25
Time: 9:00 AM
Analyst: AS

| Accredited Analysis | Results | Rating | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|--------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | A | 8/26/25 | 9:00 AM | AS | SM 9222G |
| Total coliforms: | 0/100mls | A | 8/26/25 | 9:00 AM | AS | SM 9222B |
| Standard plate count: | 0/ml | A | 8/25/25 | 3:50 PM | AS | SM 9215B |

| Field Analysis | Results | Rating | Date/Time | | Analyst | Method |
|----------------|----------|--------|-----------|----------|---------|--------|
| pH: | 7.8 SU | C | 8/25/25 | 12:30 PM | EJ | DPD |
| Chlorine: | 8.0 mg/l | E | 8/25/25 | 12:30 PM | EJ | DPD |
| Turbidity: | 1 NTU | A | 8/25/25 | 12:30 PM | EJ | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor