



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2226**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:* *Glencannon*

*Date:* *8/26/25*

*Address:* *207 Driftwood Road*  
*Canonsburg, PA 15317*

*Time:* *12:34 PM*

*Method:* *Grab*

**Sample Final Analysis**

*Matrix:* *Recreational Water*

*Date:* *8/29/25*

*Source Type:* *Wading Pool*

*Time:* *10:30 AM*

*Analyst:* *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	8/27/25	12:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/25	12:00 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/26/25	5:30 PM	AS	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.4 SU	7.2 - 7.8 SU	8/26/25	12:34 PM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/26/25	12:34 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/25	12:34 PM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor