



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 240

Customer

Facility Name: Norwin High School
Address: 251 McMahon Dr.
Huntingdon, PA 15642

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 1/19/26
Time: 8:37 AM
Method: Grab

Sample Final Analysis

Date: 1/22/26
Time: 11:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/20/26	10:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/20/26	10:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	1/19/26	3:56 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	1/19/26	8:37 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	1/19/26	8:37 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/19/26	8:37 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor