



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3**

**Lab# 2451**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:* *Rose Garden*

*Date:* *6/10/25*

*Address:* *129 Canterbury Ln.*  
*Canonsburg, PA 15317*

*Time:* *10:22 AM*

*Method:* *Grab*

**Sample Final Analysis**

*Matrix:* *Recreational Water*

*Date:* *6/13/25*

*Time:* *9:30 AM*

*Source Type:* *Pool*

*Analyst:* *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	6/11/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	5:50 PM	SL	SM 9215B
<b>Additional Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.6 SU	7.2 - 7.8 SU	6/10/25	10:22 AM	AF	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/10/25	10:22 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	10:22 AM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3**

**Lab# 2451**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Rose Garden*

*Date: 6/10/25*

*Time: 10:22 AM*

*Address: 129 Canterbury Ln.*  
*Canonsburg, PA 15317*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 6/13/25*

*Time: 9:30 AM*

*Source Type: Pool*

*Analyst: AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	5:50 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/10/25	10:22 AM	AF	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/10/25	10:22 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	10:22 AM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor