



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 309**

**Customer**

**Facility Name:** University Prep Middle School

**Address:** 3117 Centre Ave.  
Pittsburgh, PA 15219

**Matrix:** Recreational Water

**Source Type:** Pool Deep

**Sample Collection**

**Date:** 7/30/25

**Time:** 11:17 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 8/1/25

**Time:** 3:30 PM

**Analyst:** AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/30/25	4:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	A	7/30/25	4:30 PM	SL	SM 9222B
Standard plate count:	0/ml	A	7/30/25	4:50 PM	EB	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	7/30/25	11:17 AM	CW	DPD
Chlorine:	3.0 mg/l	A	7/30/25	11:17 AM	CW	DPD
Turbidity:	1 NTU	A	7/30/25	11:17 AM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 309**

**Customer**

**Facility Name:** University Prep Middle School

**Address:** 3117 Centre Ave.  
Pittsburgh, PA 15219

**Matrix:** Recreational Water

**Source Type:** Pool Deep

**Sample Collection**

**Date:** 7/30/25

**Time:** 11:17 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 8/1/25

**Time:** 3:30 PM

**Analyst:** AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/30/25	4:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	A	7/30/25	4:30 PM	SL	SM 9222B
Standard plate count:	0/ml	A	7/30/25	4:50 PM	EB	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	7/30/25	11:17 AM	CW	DPD
Chlorine:	3.0 mg/l	A	7/30/25	11:17 AM	CW	DPD
Turbidity:	1 NTU	A	7/30/25	11:17 AM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor