1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2471

Customer

		Sample Collection	
Facility Name:	*Schenley*	*Date:*	*6/24/25*
		Time:	*10:45 AM*
Address:	*1 Overlook Dr.*	*Method:*	*Grab*
	Pittsburgh, PA 15213		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*6/27/25*
		Time:	*9:20 AM*
Source Type:	*Shallow End*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	3:59 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	6/24/25	10:45 AM	WB	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/24/25	10:45 AM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	10:45 AM	WB	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2471

Customer

Facility Name:	*Schenley*
Address:	*1 Overlook Dr.*
	Pittsburgh, PA 15213
Matrix:	*Recreational Water*
Source Type:	*Shallow End*

Sample Collection

Date:	*6/24/25*
Time:	*10:45 AM*
Method:	*Grab*

Sample Final Analysis

Date:	*6/27/25*
Time:	*9:20 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	3:59 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	6/24/25	10:45 AM	WB	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/24/25	10:45 AM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	10:45 AM	WB	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor