

## **Dream Pools and Spas** 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

W-11

Lab ID No. 02-04041

Lab# 415

Customer Facility Name:

Address:

Drury Hotel

101 Ridge Rd.

Pittsburgh, PA 15205

Recreational Water Matrix:

Source Type: Pool Sample Collection

Date: Time:

9:15 AM Method: Grab

7/8/25

Sample Final Analysis

7/11/25

Time: 9:00 AM

AS Analyst:

Accredited Analysis Results		Reporting limit Incubation Date/Tim		te/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/9/25	9:00 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	7/9/25	9:00 AM	EB	SM 9222B	
Standard plate count:	200/ml	200/ml	7/8/25	3:28 PM	АН	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/8/25	9:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/8/25	9:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	9:15 AM	VH	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## **Dream Pools and Spas** 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

W-11

Lab ID No. 02-04041

Lab# 415

Customer Facility Name:

Address:

Drury Hotel

101 Ridge Rd.

Pittsburgh, PA 15205

Recreational Water Matrix:

Source Type: Pool Sample Collection

Date: Time:

9:15 AM Method: Grab

7/8/25

Sample Final Analysis

7/11/25

Time: 9:00 AM

AS Analyst:

Accredited Analysis Results		Reporting limit Incubation Date/Tim		te/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/9/25	9:00 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	7/9/25	9:00 AM	EB	SM 9222B	
Standard plate count:	200/ml	200/ml	7/8/25	3:28 PM	АН	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/8/25	9:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/8/25	9:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	9:15 AM	VH	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor