



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 1**

**Lab# 2063**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Brook Park Swim Club*

*Date: 5/29/25*

*Address: 8190 Rochester Rd*  
*Pittsburgh, PA 15237*

*Time: 11:05 AM*

*Method: Grab*

*Matrix: Recreational Water*

**Sample Final Analysis**

*Date: 5/31/25*

*Time: 3:30 PM*

*Source Type: Shallow End*

*Analyst: AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	5/29/25	5:00 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	5:00 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/25	4:40 PM	SL	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.8 SU	7.2 - 7.8 SU	5/29/25	11:05 AM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/29/25	11:05 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/29/25	11:05 AM	SL	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 1**

**Lab# 2063**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Brook Park Swim Club*

*Date: 5/29/25*

*Time: 11:05 AM*

*Address: 8190 Rochester Rd*  
*Pittsburgh, PA 15237*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 5/31/25*

*Time: 3:30 PM*

*Source Type: Shallow End*

*Analyst: AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	5/29/25	5:00 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	5:00 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/25	4:40 PM	SL	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.8 SU	7.2 - 7.8 SU	5/29/25	11:05 AM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/29/25	11:05 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/29/25	11:05 AM	SL	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor