



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 1**

**Lab# 2024**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Avalon Boro*  
*Address: 629 New Brighton Rd.*  
*Avalon, PA 15202*

*Date: 5/27/25*  
*Time: 10:38 AM*  
*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*  
*Source Type: Shallow End*

*Date: 5/30/25*  
*Time: 9:00 AM*  
*Analyst: AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25 11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25 11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25 7:00 PM	AS	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	5/27/25 10:38 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/27/25 10:38 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25 10:38 AM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 1**

**Lab# 2024**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Avalon Boro*  
*Address: 629 New Brighton Rd.*  
*Avalon, PA 15202*

*Date: 5/27/25*  
*Time: 10:38 AM*  
*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*  
*Source Type: Shallow End*

*Date: 5/30/25*  
*Time: 9:00 AM*  
*Analyst: AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25 11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25 11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25 7:00 PM	AS	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	5/27/25 10:38 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/27/25 10:38 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25 10:38 AM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor