



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 1**

**Lab# 2756**

**Customer**                      *American Pools Management*  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

**Sample Collection**

*Facility Name:*                      *Artisan at Robinson*  
  
*Address:*                              *301 Hightower Blvd.*  
   *Pittsburgh, PA 15205*

*Date:*                                      *5/27/25*  
*Time:*                                    *7:30 AM*  
*Method:*                                *Grab*

**Sample Final Analysis**

*Matrix:*                                *Recreational Water*  
  
*Source Type:*                        *Pool*

*Date:*                                    *5/30/25*  
*Time:*                                   *9:00 AM*  
*Analyst:*                                *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	5/28/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	2:55 PM	AH	SM 9215B
<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	8.0 SU	7.2 - 7.8 SU	5/27/25	7:30 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/27/25	7:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	7:30 AM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 1**

**Lab# 2756**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:*      *Artisan at Robinson*  
  
*Address:*      *301 Hightower Blvd.*  
*Pittsburgh, PA 15205*

*Date:*      *5/27/25*  
*Time:*      *7:30 AM*  
*Method:*      *Grab*

**Sample Final Analysis**

*Matrix:*      *Recreational Water*  
  
*Source Type:*      *Pool*

*Date:*      *5/30/25*  
*Time:*      *9:00 AM*  
*Analyst:*      *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	5/28/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	2:55 PM	AH	SM 9215B
<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	8.0 SU	7.2 - 7.8 SU	5/27/25	7:30 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/27/25	7:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	7:30 AM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor