



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 452**

**Customer**

Facility Name: Doubletree Cranberry

Address: 910 Sheraton Dr  
Mars, PA 16046

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 7/7/25

Time: 10:08 AM

Method: Grab

**Sample Final Analysis**

Date: 7/10/25

Time: 9:30 AM

Analyst: #REF!

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	3:58 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/7/25	10:08 AM	ZR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/25	10:08 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	10:08 AM	ZR	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 452**

**Customer**

Facility Name: Doubletree Cranberry

Address: 910 Sheraton Dr  
Mars, PA 16046

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 7/7/25

Time: 10:08 AM

Method: Grab

**Sample Final Analysis**

Date: 7/10/25

Time: 9:30 AM

Analyst: #REF!

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25 9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25 9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25 3:58 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/7/25 10:08 AM	ZR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/25 10:08 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25 10:08 AM	ZR	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*