



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-13**

**Lab# 2436**

**Customer**

**Facility Name:** Trellis North Fayette  
**Address:** 1500 Park Lane Drive  
Pittsburgh, PA 15275

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 8/12/25  
**Time:** 10:23 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 8/15/25  
**Time:** 9:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25 10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25 10:30 AM	EB	SM 9222B
Standard plate count:	200/ml	200/ml	8/12/25 3:58 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/13/25 11:30 AM	EB	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/12/25 10:23 AM	AH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	8/12/25 10:23 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25 10:23 AM	AH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-13**

**Lab# 2436**

**Customer**

Facility Name: Trellis North Fayette

Address: 1500 Park Lane Drive  
Pittsburgh, PA 15275

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 8/12/25

Time: 10:23 AM

Method: Grab

**Sample Final Analysis**

Date: 8/15/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25 10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25 10:30 AM	EB	SM 9222B
Standard plate count:	200/ml	200/ml	8/12/25 3:58 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/13/25 11:30 AM	EB	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/12/25 10:23 AM	AH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	8/12/25 10:23 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25 10:23 AM	AH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor