



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 216

Customer

Facility Name: Longwood at Oakmont

Address: 500 Route 909
Verona, PA 15147

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/8/25

Time: 2:35 PM

Method: Grab

Sample Final Analysis

Date: 7/11/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	5:35 PM	EB	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/9/25	11:00 AM	AH	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/8/25	2:35 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/8/25	2:35 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	2:35 PM	BH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 216

Customer

Facility Name: Longwood at Oakmont

Address: 500 Route 909
Verona, PA 15147

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/8/25

Time: 2:35 PM

Method: Grab

Sample Final Analysis

Date: 7/11/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	5:35 PM	EB	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/9/25	11:00 AM	AH	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/8/25	2:35 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/8/25	2:35 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	2:35 PM	BH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor